

**ADDENDUM NO. 1**

**BID NO. 021-19 SUBSTATION REGULATORS FOR  
PROJECT EL003-17**

**CITY OF FAIRHOPE  
FAIRHOPE, ALABAMA**

**APRIL 25, 2019**

The Owner hereby requests pricing for Item C, for consideration as an alternative to Item A.

**A. GENERAL – TWELVE (12) REGULATORS**

**3. Bid Item C.**

Regulators shall be Siemens Type JFR Catalog #10-07.6-833 rated 833 KVA, 7200 Volts, 95 KV BIL, 1093 Amps, single-phase with  $\pm$  10% regulation. Regulators shall be FR3 Fluid Filled, 60 Hertz, 55 degrees Celsius rise by resistance (no fans). Ship wired for connection at 7200 Volts.

Find attached an updated Bid Form reflecting this addition.

Bidder must submit signed copy of this addendum with bid proposal.

---

Bidder

---

Date

END OF ADDENDUM NO. 1

STEWART ENGINEERING, INC.  
Lance Junkin

BID FORM  
**BID No. 021-19 SUB STATION REGULATORS FOR  
PROJECT EL003-17**

FAIRHOPE, ALABAMA

**A. Nine (9) – Regulators - 889 KVA (7.2 KV) – FR3 Fluid Filled (ONAN)**

9 @ \$ \_\_\_\_\_ Each \$ \_\_\_\_\_  
Total

Brand Quoted: \_\_\_\_\_

No Load Losses (Watts @ Neutral): \_\_\_\_\_

No Load Losses (Watts @ 1 R): \_\_\_\_\_

Load Losses (Watts @ 15 R): \_\_\_\_\_

Load Losses (Watts @ 16 R): \_\_\_\_\_

Load Losses (Watts @ 15 L): \_\_\_\_\_

Load Losses (Watts @ 16 L): \_\_\_\_\_

Are all accessories shipped with regulators (YES/NO)? \_\_\_\_\_

Warranty Quoted (Time): \_\_\_\_\_

Shipment Quoted (Time): \_\_\_\_\_

Exceptions: \_\_\_\_\_

\_\_\_\_\_

CITY OF FAIRHOPE  
FAIRHOPE, ALABAMA

**B.** Three (3) – Regulators - 416 KVA (7.2 KV) – FR3 Fluid Filled (ONAF)

3 @ \$ \_\_\_\_\_ Each \$ \_\_\_\_\_  
Total

Brand Quoted: \_\_\_\_\_

No Load Losses (Watts @ Neutral): \_\_\_\_\_

No Load Losses (Watts @ 1 R): \_\_\_\_\_

Load Losses (Watts @ 15 R): \_\_\_\_\_

Load Losses (Watts @ 16 R): \_\_\_\_\_

Load Losses (Watts @ 15 L): \_\_\_\_\_

Load Losses (Watts @ 16 L): \_\_\_\_\_

Are all accessories shipped with regulators (YES/NO)? \_\_\_\_\_

Warranty Quoted (Time): \_\_\_\_\_

Shipment Quoted (Time): \_\_\_\_\_

Exceptions: \_\_\_\_\_

\_\_\_\_\_

CITY OF FAIRHOPE  
FAIRHOPE, ALABAMA

C. Nine (9) – Regulators - 833 KVA (7.2 KV) – FR3 Fluid Filled (ONAN)

9 @ \$ \_\_\_\_\_ Each \$ \_\_\_\_\_  
Total

Brand Quoted: \_\_\_\_\_

No Load Losses (Watts @ Neutral): \_\_\_\_\_

No Load Losses (Watts @ 1 R): \_\_\_\_\_

Load Losses (Watts @ 15 R): \_\_\_\_\_

Load Losses (Watts @ 16 R): \_\_\_\_\_

Load Losses (Watts @ 15 L): \_\_\_\_\_

Load Losses (Watts @ 16 L): \_\_\_\_\_

Are all accessories shipped with regulators (YES/NO)? \_\_\_\_\_

Warranty Quoted (Time): \_\_\_\_\_

Shipment Quoted (Time): \_\_\_\_\_

Exceptions: \_\_\_\_\_

\_\_\_\_\_