

ADDENDUM NO 03
Bid No 019-14 Manhole—Wet Well Rehabilitation 2014
CITY OF FAIRHOPE

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

Answer provided by Mr. Dan McCrory, Superintendent, Water and Sewer Department:

Questions from potential bidders:

Question 1:

We would feel much better about submitting a competitive bid if a pre-approval of our system was provided pre-bid by addendum versus a post bid review while comparing liner systems based on physical characteristics rather than merit and case history. Is this something that you all would consider?

Answer 1:

There are no pre-approvals; please bid as stated.

Correction:

In Addendum No.1,

Change from:

- 8.12.3 **Rehabilitate 48” Manhole at Nichols/Young Street** (Approx. depth 4 ‘)
- Repair all leaks, voids and any signs of infiltration encountered
 - Rebuild manhole bottom and re-establish flow channel
 - Apply approx. 1" of cementitious underlayment
 - Apply approx. 150 mils (1/8") of SprayWall urethane topcoat or approved equal product

Change to: (increases depth to approx. 14’)

- 8.12.3 **Rehabilitate 48” Manhole at Nichols/Young Street** (Approx. depth 14 ‘)
- Repair all leaks, voids and any signs of infiltration encountered
 - Rebuild manhole bottom and re-establish flow channel
 - Apply approx. 1" of cementitious underlayment
 - Apply approx. 150 mils (1/8") of SprayWall urethane topcoat or approved equal product

Bidders are to sign and include signed **Addendum No.3** with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
06-04-2014