

ADDENDUM NO 01
CITY OF FAIRHOPE
To
RFQ NO. 007-12

PAD AND POLE MOUNT TRANSFORMERS
FOR ELECTRIC DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

Answers from Scott Sligh, Electric Department Superintendent.

Questions from potential bidders:

Question 1:

Is the temperature rise indicated below correct at 85C?

Technical Specifications for Three Phase Pad Mount Distribution Transformers

1. Each transformer shall be equipped with a non-resettable device which detects and provides external indication of internal transformer faults, and also incorporates pressure relief functionality.

The approved device is manufactured by IFD Corporation or approved equal.

2. THE TRANSFORMERS WILL INCLUDE THE FOLLOWING:

a. Three Phase Pad Mount Distribution Transformer

i. Size 300 KVA

ii. The above listed transformers will COMPLY include the following features:

(YES/NO)

iii. 60 Hz _____

iv. 85" C Rise _____

Answer 1:

No, 85 degrees C is not correct. The correct number is 65 degrees C.

Responders are to sign and include signed Addendum No.1 with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 04-11-12