

**ADDENDUM NO. 02**  
**to**  
**Bid No. 011-15 Class 200 SDR21 PVC Pipe**

CITY OF FAIRHOPE, AL

Answers to questions provided by City Engineer, Trey Jinright,  
The bid documents for this Bid shall be amended, revised and changed in the following particulars:

**QUESTIONS FROM POTENTIAL BIDDERS:**

**Question No. 1:**

“I do not see anywhere in the specs where it says if the pipe is to be gasketed or solvent weld.”

**Answer to Question No. 1**

It is gasket.

**Question No. 2:**

“Also is it permitted for drop shipment as long as we have a representative on site upon delivery?”

**Answer to Question No. 2**

Drop shipment would need to be coordinated with City and Contractor.

=====

Bidders are to sign and include signed Addendum No.2 with submitted bid documents.

Daniel P. Ames  
Purchasing Manager  
City of Fairhope  
Posted: 01-16-15

Acknowledged:

\_\_\_\_\_  
(Company)

\_\_\_\_\_  
(By)