

ADDENDUM NO 02

CITY OF FAIRHOPE

To

BID NO. 029-10 FEMA REPAIR S. MOBILE ST.

FOR THE PUBLIC WORKS DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

Answers from the Public Works Department:

Question 1:

How much is the disposal fee?

Answer 1:

From the Public Works Dept:

No disposal fee for waste fill materials.

Question 2:

“The beach seawall repair bid calls for “structural backfill”. Please clarify what type of soil is required for this repair.”

Answer 2:

From the Public Works Dept:

No red dirt is allowed in the close proximity of the Bay. Only compactable fill with 10% or less red material, is allowed on this project. (This applies to all projects)

Question 3:

“Do you know of a vendor for the wooden guardrail?”

Answer 3:

From the Public Works Dept:

Requires contractor research.

Responders are to sign and include signed Addendum No.1 with submitted bid documents.

Acknowledged:

Company

By

Daniel P. Ames
Purchasing Manager
City of Fairhope
Posted: 08-10-2010