

**ADDENDUM NO 03**  
CITY OF FAIRHOPE  
To

BID NO. 030-10 FEMA REPAIR BEACH SEAWALL  
FOR THE PUBLIC WORKS DEPARTMENT

The bid documents for this Bid shall be amended, revised and changed in the following particulars:

**Question from potential bidder:**

**Question 1:**

How much is the disposal fee?

**Answer 1:**

From the Public Works Dept:

No disposal fee for waste fill materials.

**Question 2:**

“The beach seawall repair bid calls for “structural backfill”. Please clarify what type of soil is required for this repair.”

**Answer 2:**

From the Public Works Dept:

No red dirt is allowed in the close proximity of the Bay. Only compactable fill with 10% or less red material, is allowed on this project.

**Responders are to sign and include signed Addendum No.1 with submitted bid documents.**

Acknowledged:

\_\_\_\_\_  
Company

\_\_\_\_\_  
By

Daniel P. Ames  
Purchasing Manager  
City of Fairhope  
Posted: 08-10-2010